

# Your Comment on Melia Place

All sections of this form with an asterisk (\*) are mandatory.

## 1. Contact Details

Please ensure that you have authority to comment on the application on behalf of those named on this form.

|  |  |                    |                      |
|--|--|--------------------|----------------------|
| <b>Organisation name (if relevant)</b>   | Watercare Services Limited   |                    |                      |
| <b>*First name</b>   | Amir   |                    |                      |
| <b>*Last name</b>  | Karimi   |                    |                      |
| <b>Postal address</b>  | 73 Remuera Road, Remuera, Auckland 1050, New Zealand                 |                    |                      |
| <b>*Home phone / Mobile phone</b>  | <input type="text"/>   | <b>*Work phone</b> | <input type="text"/> |
| <b>*Email (a valid email address enables us to communicate efficiently with you)</b> | <a href="mailto:Amir.karimi@water.co.nz">Amir.karimi@water.co.nz</a> |                    |                      |

## 2. \*We will email you draft conditions of consent for your comment

|                                     |  |                          |  |
|-------------------------------------|--|--------------------------|--|
| <input checked="" type="checkbox"/> | I can receive emails and my email address is correct | <input type="checkbox"/> | I cannot receive emails and my postal address is correct |
|-------------------------------------|--|--------------------------|--|

## 3. Please provide your comments on this application

Watercare has reviewed the provided information for the fast track consenting application in relation to Watercare's ability to provide water and wastewater services to the proposed 59 residential unit development at 20 Melia Place Stanmore Bay development and the proposed upgrade/alteration to our networks set out in the application, in particular to the Infrastructure Report dated 18/11/2021 by Civix.

Subject to the conditions below, we confirm that there is sufficient capacity in the current water and wastewater network to service the proposed development as of today's date.

- All public water supply and wastewater works required to service this subdivision/development shall be designed and constructed by the developer at no cost to Watercare.
- No building is allowed over the existing or proposed wastewater lines. All the current lines must be relocated clear of the proposed buildings' footprint.
- A private hydrant(s) will be required as the distance between the furthest dwelling entrance and the first available hydrant is more than 135m.
- Any connection to the development will need to be an extension off the existing 125mm PE watermain on Melia Place and not made to the smaller rider main.